

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:26 pm

PWS ID: UTAH19037 **Name:** WIND WHISTLE CAMPGROUND
Legal Contact: BLM - UTAH STATE OFFICE **Rating:** Approved
TRENT DUNCAN **Rating Date:** 04/09/1996
Address: PO BOX 45155 **Activity Status:** Active
SALT LAKE CITY, UT 84145-0155
Phone Number: 801-539-4001
City Served (Area):
County: SAN JUAN COUNTY
System Type: Non-community **Last Inv Update:** 07/18/2011 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 06/29/2010 **Total Dsgn Cap:**
Population: 39 **Surveyor:** MARK BERTELSON **Total Emerg Cap:**
Oper Period: 5/1 to 9/30

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	DUNCAN, TRENT	CIVIL ENGINEER	435-539-4090		TRENT_DUNCAN@BLM.GC

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Combined	Unknown	0	3
Residential	Unknown	0	1
			4 Total Svc Connections

Storage

Total Storage: 5,000 GAL **Number of Units:** 1 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	WIND WHISTLE STORAGE TANK	Ground	5,000 GAL	Steel		A	

Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	WIND WHISTLE WELL	Active	WL	6	25 GPM		Yes	GW	Seasonal	5/1 to 9/30	

*Reports measured flow for wells, approved design capacity for all other sources.